

**Minutes Approved:** \_\_\_\_\_

***BOARD OF HEALTH  
MEETING MINUTES  
March 21, 2011***

The Board of Health met at **6:00 pm** at the Ritter Administration Building

Present: Chairman George Emond, David Shea, Jack Rabbitt and Troy Daniels

**TITLE 5 INSPECTION REPORTS REVIEWED:**

None

**SEPTIC PERMITS SIGNED:**

229 Lancaster Avenue

**229 LANCASTER AVENUE – SEPTIC VARIANCES**

Dan Proctor met with the board of behalf of the owner, Marilyn Stokes. This sewage disposal system has failed a Title 5 Inspection. Soil testing was conducted in preparation for the design of a new system and at the time the soil was too damp to perc. A soil sample was taken and a sieve analysis was performed.

The sewer line servicing the system is too close to the pressure water line of the Lunenburg Water District, 5 feet instead of 10 feet.

Should the building sewer line need to be replaced, Jim Garreffi is requesting that same be sleeved as it passes the water line.

After discussion and on Motion by Shea and second by Daniels, variances were approved. All in favor.

Meeting adjourned at 6:45 pm.